

University of Asia Pacific
 Environmental Engineering Laboratory
 Department of Civil Engineering
 Monthly water quality parameter report

Date: September 27, 2017

Prepared by: Dr. TanveerFerdousSaeed
Associate Professor and Lab-in-charge
Environmental Engg.Lab, Department of Civil Engg.

SL No	Water Quality Parameters	Unit	Concentration		Bangladesh Standard for Drinking Water (ECR, 1997)	Remarks
			Filter Water	Tap Water		
1	pH		7.57	7.45	6.5-8.5	OK
2	Color	Pt-Co	0.0	0.0	15	OK
3	Turbidity	JTU	0.0	9.48	10	OK
4	Alkalinity (as CaCO ₃)	mg/L	262	264	---	
5	Iron	mg/L	0.02	0.51	0.3-1.0	OK
6	Electrical Conductivity (EC)	μS/cm	432	420	---	---
7	Dissolve Oxygen (DO)	mg/L	6.98	6.78	6	OK
8	Total Hardness (as CaCO ₃)	mg/L	112	117	200-500	OK
9	Chloride (Cl ⁻)	mg/L	88.59	95.10	150-600	OK
10	Chemical Oxygen Demand (COD)	mg/L	1	2	4	OK
11	Total Dissolved Solids	mg/L	200	202	1000	OK
12	Suspended Solids	mg/L	0	5.0	10	OK
13	Ammonia Nitrogen (NH ₃ -N)	mg/L	0.06	0.12	0.5	OK
14	Nitrite Nitrogen (NO ₂ -N)	mg/L	0.004	0.002	<1.0	OK
15	Nitrate Nitrogen (NO ₃ -N)	mg/L	0.5	0.4	10	OK
16	Sulfate (SO ₄ ²⁻)	mg/L	5.0	5.0	400	OK
17	Phosphate (PO ₄)	mg/L	0	0.0	6	OK
18	Free Chlorine	mg/L	0.01	0.01	0.2	
19	Temperature	°C	22.9	22.8	20-30	OK
20	Fecal Coliform (E. Coli)	CFU/100 mL	Not measured		0	