

University of Asia Pacific
 Environmental Engineering Laboratory
 Department of Civil Engineering
 Monthly water quality parameter report

Date: May 23, 2018

Prepared by: Dr. Tanveer Ferdous Saeed
Associate Professor and Lab-in-charge
Environmental Engg.Lab, Department of Civil Engg.

SL No	Water Quality Parameters	Unit	Concentration		Bangladesh Standard for Drinking Water (ECR, 1997)	Remarks
			<i>Civil Filter</i>	<i>CafeFilter</i>		
1	pH		7.39	7.23	6.5-8.5	OK
2	Color	Pt-Co	2	2	15	OK
3	Turbidity	JTU	0.0	0.0	10	OK
4	Alkalinity (as CaCO ₃)	mg/L	101	105	---	---
5	Iron	mg/L	0.16	0.09	0.3-1.0	OK
6	Electrical Conductivity (EC)	μS/cm	560	304	---	---
7	Dissolve Oxygen (DO)	mg/L	6.25	6.23	6	OK
8	Total Hardness (as CaCO ₃)	mg/L	190	187	200-500	OK
9	Chloride (Cl ⁻)	mg/L	85	90	150-600	OK
10	Chemical Oxygen Demand (COD)	mg/L	Not measured		4	
11	Total Dissolved Solids	mg/L	258	141	1000	OK
12	Suspended Solids	mg/L	0.0	0.0	10	OK
13	Ammonia Nitrogen (NH ₃ -N)	mg/L	0.05	0.06	0.5	OK
14	Nitrite Nitrogen (NO ₂ -N)	mg/L	0.005	0.006	<1.0	OK
15	Nitrate Nitrogen (NO ₃ -N)	mg/L	0.8	0.7	10	OK
16	Sulfate (SO ₄ ²⁻)	mg/L	11.0	6.0	400	OK
17	Phosphate (PO ₄)	mg/L	0.0	0.0	6	OK
18	Free Chlorine	mg/L	0.01	0.01	0.2	OK
19	Temperature	°C	26.5	26.2	20-30	OK
20	Fecal Coliform (E. Coli)	CFU/100 mL	0.0	0.0	0	OK

Samples Analyzed By: Md. Shahadat Hossain, Technician, Environmental Engineering and Chemistry Laboratory